

## ELMIRA WATER BOARD

Elmira, New York

Bids for Estimated 2019 Requirements for:

### SPECIFICATIONS

#### **COPPER COMPRESSION COUPLINGS, COPPER COMPRESSION CORPORATION STOPS**

will be received by the Elmira Water Board at its office at 261 West Water Street, Elmira, New York 14901 until 1:30 P.M., EST, on Wednesday, October 24, 2018. At this time the bids will be publicly opened and read.

The copper coils shall be 3/4" diameter, type K soft copper in coils of 60' and shall be in conformance with ANSI/NSF-61-25XN and ASTM B-88.

The copper compression couplings shall be 3/4" in diameter, Ford C-44-33-Q or Mueller H-15403 ONLY.

The copper compression corporation stops shall be 3/4" in diameter, Ford part #F1100-3-G or Muller H-15028 ONLY.

The copper compression curb stops shall be 3/4" Ford part #B44-333-Q or Muller part #300 ball valve, ball valve type with quick joint ends ONLY.

The copper compression couplings, and copper compression corporation stops will be ordered as one shipment not to exceed 60 days from award confirmation date, and are to be delivered to the Elmira Water Board Maintenance Shop at 760 Bonview Street, Elmira, New York.

Bids shall be quoted on the below quotation form. Bid price should include freight delivered to the Elmira Water Board's Maintenance Shop yard at 760 Bonview Street, Elmira, New York.

**Bids must be in sealed envelopes, ATTN: Denise Mullaney, and the quoted material designated on the outside of the envelope.** Standard Non-Collusive Bidding Certificate, Waiver of Immunity and Certification of Bidder regarding Equal Employment Opportunity must be signed and submitted with the bid.

The Elmira Water Board reserves the right to waive any informalities and to reject any or all bids and to re-advertise for new bids at its discretion.

BID SHEET

**Copper Compression Couplings,  
Copper Compression Corporation Stops**

BIDDER NAME: \_\_\_\_\_

Phone: \_\_\_\_\_ Fax: \_\_\_\_\_

Email: \_\_\_\_\_

QUOTATION FORM

| <u># Of Units</u>                 | <u>Size</u> | <u>Cost/Unit</u> | <u>Extended Total</u> |
|-----------------------------------|-------------|------------------|-----------------------|
| 3,000' Type "K" copper 60ft coils | 3/4"        | _____            | _____                 |
| 120 couplings (each)              | 3/4"        | _____            | _____                 |
| 120 corporation stops (each)      | 3/4"        | _____            | _____                 |
| 120 compression curb stop (each)  | 3/4"        | _____            | _____                 |
| TOTAL PRICE DOLLARS               |             |                  | _____                 |